



INCORPORATED COUNTY OF LOS ALAMOS

101 Camino Entrada, Building 3
Los Alamos, New Mexico 87544 (505)-63-3507
Procurement Division

January 11, 2024

TO ALL HOLDER OF SOLICITATION DOCUMENTS FOR:

Invitation for Bids No. IFB24-43
IFB Name: Wayfinding Pole Procurement

Addendum No.3

This Addendum No.3 forms a part of the Solicitation Documents and modifies, as noted below, the original Solicitation Documents identified above.

This Addendum provides questions received and the County's answers to all potential Bidders:

1. NMDOT calls out for anchor bolts with a plate for poles of 30 ft and above. Since your pole heights are 15ft and lower, we would like to confirm standard anchor bolts with a hook are acceptable?

Response: All bases shall be screw in bases with breakaway bolt kits. We will not be pouring any foundations. No J hook type anchor bolts for concrete.

2. In order to meet AASHTO & wind speed requirements called out by NMDOT, would two pole diameters to acceptable for the different sign types?

Response: Yes, two different diameter pole sizes are allowed to meet the required wind loads.

All other provisions of the Solicitation Documents shall remain unchanged. This Addendum No. 3 is hereby made a part of the Solicitation Documents to the same extent as those provisions contained in the original documents and all itemized listings thereof.

Each Respondent is requested to acknowledge receipt of this Addendum No. 3 with the Bid Forms.

I hereby acknowledge receipt of this Addendum No.3.

Signed

Print Name

Date

Title

Company