



INCORPORATED COUNTY OF LOS ALAMOS

101 Camino Entrada, Building 3
Los Alamos, New Mexico 87544 (505) 663-3507
Procurement Division

June 17, 2024

TO ALL HOLDERS OF SOLICITATION DOCUMENTS FOR:

Invitation for Bids No. IFB24-74 IFB Name: Bathtub Row Reconstruction Project

Addendum No. 2

This Addendum No. 2 forms a part of the Solicitation Documents and modifies, as noted below, the original Solicitation Documents identified above. This Addendum as well as all documentation associated with it shall be made available at the following link:

<https://lacnm.com/bids>

1. Bid item #24: Is this HDPE sewer line gravity or pressure?

RESPONSE: The HDPE sewer line is a gravity line.

2. Bid item #24 Sheet 11-35: Profile shows PVC pipe and bid form has HDPE. Could you clarify?

RESPONSE: The bid items will be HDPE as per the technical specifications item 24 and bid form description, the plan sheet has incorrectly labeled the pipe as PVC.

3. Bid item #26: What type of connection are you requiring to the manholes for the HDPE of bid item #23?

RESPONSE: The connection may be either precast or punch out in field and grout as needed per situation.

All other provisions of the Solicitation Documents shall remain unchanged. This Addendum No. 2 is hereby made a part of the Solicitation Documents to the same extent as those provisions contained in the original documents and all itemized listings thereof.

Each Respondent is requested to acknowledge receipt of this Addendum No. 2 with the Bid Forms.

I hereby acknowledge receipt of this Addendum No.2.

Signed _____ Print Name _____ Date _____

Title _____ Company _____